WEBINAR PANELISTS





MODERATOR: ANDY COFAS CUG Board Member and Plant Manager Rawhide Energy Center Platte River Power Authority




PRESENTER:

ROD HATT

Owner

Coal Combustion, Inc.

Practicalities of Coal Blending



Thank you for attending!

Measuring Coal

Engineering

COAL USERS' GROUP

1.5 meter desk






1.55 meter door

Fits through every time



Coal Quality








1.55 Meter Door

Only ½ of the people fit through

Small and Large Variability








Blending Variability









1. Economics

Cost of Blending Plant Performance

2. Fuel Quality

Is it consistent



Economics

Paper Blending Looks Good

Fuel Quality

Plant reacts to swings



How to Blend Coal

Hard to do!

Mixing verse Blending


Plant Limit




















What properties blend?

Coal Blending

Chemical Data Blends

- Heating Value
- Sulfur
- Ash Chemistry






Coal Blending

Physical Test Difficult

- Hardgrove (HGI)
- Ash Fusion Temps
- Combustion Properties







How to blend?



Mine Vessel

Yard Boiler



Blending – Coals on same belt Mixing – tons plus tons



Mine – Many Coals are blended at mine to meet specs






Mine – Similar rank Usually blend for Ash and Sulfur, other elements, CI, Na



Vessel – Blending/Mix while loading larger ship, 300/200 ton mix worked, best is blending








Vessel – Blend is delivered to plant Can't un-blend



Yard – Must have space Blend both coals on same belt Mix tons of one plus tons other Reclaim plus train/vessel





Boiler – Individual mills on Separate coals



Boiler – Blend proportion Can be adjusted daily









Boiler – Air to Fuel Ratios Should be balanced Coal flow x CV



Rod Hatt


Coal Combustion, Inc.

Rod hatt@coalcombustion.com

859-873-0188

www.coalcombustion.com

Thank you so much!



Questions?